

RF PLC - User story #2650

User story # 2592 (Code: Impl): Define communications between PLC and EPICS avoiding the use of the microbox

Architecture option: add board to replace moxa communications (converter from TCP to RS485)

26.05.2025 10:08 - Angela Salom

<b>Status:</b>	Rejected	<b>Start date:</b>	26.05.2025
<b>Priority:</b>	Normal	<b>Due date:</b>	09.06.2025
<b>Assignee:</b>	Iago Dapena	<b>% Done:</b>	0%
<b>Category:</b>		<b>Estimated time:</b>	4.00 hours
<b>Target version:</b>	Architecture definition V1.0	<b>Spent time:</b>	0.00 hour
<b>Git branch (link):</b>		<b>SVN commit (link/?p=rev):</b>	
<b>Git merge to develop (link):</b>			
<b>Description</b>			

History

#1 - 26.05.2025 11:04 - Angela Salom

- Status changed from New to Rejected

PSYS will be replaced by a new version that will accept directly TCP, so no need to add a RS485 board